

Fire Drill Report

Facility Name: FICC Children's Center Address: 2201 Hull Road, Fayetteville, NC 28303

Drill Date	Drill Time	Person Conducting Drill	Method of Notification	# Staff Members Participating	# Occupants Evacuated	Special Conditions Simulated	Problems?	Weather Conditions	Time Req for Complete Evacuation
1/9/09	5:15	H Harborough	Fire Alarm	10	75	none	none	clear & cold	3:15
2/20/09	2:35	H Harborough	Fire Alarm	30	129	none	none	clear & cold	3:15
4/30/09	10:10	H Harborough	Fire Alarm	30	133	none	none	cloudy cool	3:15
6/8/09	3:35	H Harborough	"	30	115	none	none	cloudy hot	3:15
8/28/09	10:35	H Harborough	"	30	142	"	"	"	3:17
9/28/09	11:05	H Harborough	Fire Alarm	31	152		none	Sunny hot	2:53
10/6/09	9:30	Automatic alarm went off		30	144		dirty sensor	rainy	3:10
11/19/09	10:20	Army	Fire Alarm	#32	147		* none	Sunny	3:25
12/18/09	10:00	Simpson	"	29	122		Fire Alarm Check	rainy/slow	3:10